

Improved Data Center Cooling Efficiency within a Sealed Enclosure

By Ronald Panicucci, PE
LAN Associates Engineering, Planning, Architecture, Surveying, Inc.

Today's modern data centers are large energy consumers, particularly with the movement toward higher density servers. As a result of the large energy consumption and the increased awareness of energy savings initiatives not only from the pure economic sense, but from the sustainable design perspective through the U. S. Green Building Council LEED programs and the joint U.S. Environmental Protection Agency/U.S. Department of Energy, Energy Star program, concern of improving data center cooling efficiency is rapidly increasing.

The cooling systems designed for today's data centers must operate continuously 24/7. The systems must remove heat produced by the electrical equipment, to prevent it from reaching an unacceptable level. The heat generated by the data center is the combination of heat generated by the data processing equipment, along with the infrastructure and support equipment including UPS, power distribution, air conditioning, lighting and occupants. The overall load is determined by the electrical load of the equipment and factors for lighting and occupants, typically expressed as watts/sq. ft. or watts/person. Data center cooling equipment is designed to provide air to the inlet of the computer equipment that ranges from 68° F to 77° F, with a relative humidity of 40% to 55%.

The load determination above ignores sources of environmental heat such as sunlight through windows and heat transferred through the building, and/or data center envelope. For small data or network rooms which do not have walls or windows to the outside, the building envelope effects can be ignored. However, for moderate to large data centers which typically have walls or a roof exposed to the outdoors, additional heat loads must be added to the design capacity of the air conditioning system. The parameters to be considered in the additional loads imposed by the building envelope include thermal resistance (insulation), thermal mass (heavy construction such as concrete versus light-weight steel), air-tightness, and moisture permeability.

Besides cooling, the air conditioning system provides control of the data center humidity. In an ideal situation, once the specified relative humidity is achieved, the air conditioning equipment would operate without the need to add water. However, due to the cooling of the air by the air conditioning equipment, the temperature is reduced below the dew point, and moisture is removed as a result of condensation. Then, to achieve the desired minimum relative humidity, supplemental humidification is performed. This supplemental humidification is an additional heat load with must be factored into the design capacity and operation of the system and can lead to an overdesign of up to 30%.

As a general, overall rule, it is good practice to size a cooling system for small data or network rooms based on a factor of 1.3 times the total anticipated equipment load, plus an added capacity for redundancy. However, for larger data centers, air will pass into the interior of the data center, through cracks and other unsealed openings in the building and data center envelope. The primary areas of leakage tend to be at gaps around windows and doors, joints in building façade elements, wall/roof junctures, utility penetrations and other areas where it is difficult to develop an air-tight seal. This type of leakage and losses is typical for many of today's larger data centers and is common for co-location type facilities which are often constructed within large warehouse or industrial type buildings rather than in better constructed commercial or office type spaces. Such leakage will have a negative impact on indoor temperature and humidity, must be accounted for in the design process, and provides for an area of improvement to increase the efficiency of conventional air conditioning systems.

The analysis described above takes into consideration the rated equipment loads, peak demands and steady-state conditions that are just representative "snapshots" of data center performance. However, this simplified analysis does not provide the designer with information regarding the dynamics of indoor temperature and humidity, two of the most crucial factors necessary to accurately design an efficient data center cooling system.

One means of eliminating the dynamic factors and simplifying the design is to construct the data center within a sealed enclosure. By constructing the data center within a well insulated, air-tight, water-tight, hermetically sealed enclosure, the effects of environmental heat, infiltration and humidity fluctuations can be reduced considerably, if not eliminated.

The example below compares the environmental heat load of a 5,000 square foot data center constructed conventionally to that of an iFortress enclosure with R-22 insulation and sealed construction. The analysis shows that the Modular MCF iFortress™, which is a sealed assembly that provides an R22 insulation value, results in a sensible heat loss reduction of 60% over the conventionally built facility. Also, because the iFortress enclosure results in an airtight, water tight, hermetically sealed enclosure, infiltration is eliminated, thereby reducing the effects of fluctuations in humidity, providing for increased efficiency. Based on the reduction in environmental heat load alone, a minimum increase in overall cooling load efficiency of 9% can be expected (As indicated above, it is good practice to overdesign the system by 30%. The 60% reduction results in an overdesign of 0.3 x 0.6, or 0.18. A design factor of 1.18 compared to 1.3 is a reduction of 9%).

In addition to the above note efficiencies that are gained by a sealed iFortress enclosure, there is virtually 100% efficiency gained on the energy that is consumed to maintain a positive level of pressure within a conventionally built facility. This expense, along with the installation of vapor barriers within conventional walls, is a common practice used to maintain as "humidity free" an environment as possible for data centers, as well as reduce the infiltration of dirt and dust from adjacent spaces. Because the panels are engineered to withstand elements such as humidity and the assemblies are sealed, the pressure established within the assemblies is constant, and therefore, there is no need for these pressurization efforts. As such, this consumption of energy, used as a form of standard operating procedure in data centers, is eliminated in its entirety, thereby netting a 100% efficiency gain.

iFORTRESS/CONVENTIONAL CONSTRUCTION DATA CENTER COMPARATIVE

COOLING LOAD CALCULATIONS - FOR ONLY THE BUILDING ENVELOPE

LENGTH AND WIDTH (FEET)	50	100
CONVENTIONAL BLDG HEIGHT (FEET)	20	
iFORTRESS HEIGHT (FEET)	10	
PERIMETER (FEET)	300	
(SF)	5,000	
ENERGY COST (PER KW HOUR)	0.12	
CONSUMPTION REDUCTION:	60%	

**BASED ON STD GYP BOARD CONSTRUCTION/CONCRETE ROOF DECK
Standard Conventional Roof (R10)/Interior Slab (R2) r Value**

	AREA (FT2)	PERIMETER (FEET)	HEIGHT (FEET)	U VALUE	DELTA TEMP (F)	WATTS/ SF	WATTS	SENSIBLE LOAD BTUH
		300	20	0.067	20			8,040
CEILING/ROOF	5,000			0.1	20			10,000
								18,040

BASED ON iFORTRESS CONSTRUCTION (R-22)

	AREA (FT2)	PERIMETER (FEET)	HEIGHT (FEET)	U VALUE	DELTA TEMP (F)	WATTS/ SF	WATTS	SENSIBLE LOAD BTUH
		300	10	0.05	20			2,727
CEILING/ROOF	5,000			0.05	20			4,545
								7,273

NOTES:

01. IT IS ASSUMED THAT THE COMPARISON IS FOR A SPACE WITH NO GLASS WINDOWS.
02. THE ABOVE CALCULATIONS ARE ONLY BASED ON BUILDING ENVELOPE.
03. TOTAL COOLING LOAD CONVERSION INTO KWH IS BASED ON 12,000 BTUH SENSIBLE LOAD = 1 TON)
04. A.C. UNIT ELECTRICAL CONSUMPTION HAS BEEN TAKEN AS 0.9 KW/TON